

COMPLETE PFAS SAMPLING RESULTS

Contaminant of Concern (ng/L)	ADEC Action Levels	Public Water System Source by Community														
		Ambler		Buckland	Deering	Kiana		Kivalina	Kobuk	Kotzebue		Noatak		Noorvik	Selawik	Shungnak
		2002 Well	1982 Well	Buckland River	Inmachuk River	Upper Well	Lower Well	Wulik River	Main Well	Devils Lake	Vortac Lake	Well # 5	Well # 6	Kobuk River	Selawik River	Kobuk River
PFOA	Combination of the analytes should not exceed 70 ng/L	0.31	0.36	ND	ND	ND	ND	ND	0.32	ND	ND	ND	ND	0.23	0.41	ND
PFOS		ND	ND	ND	ND	ND	ND	ND	0.29	ND	ND	ND	ND	ND	0.43	ND
PFHpA	No Action Levels	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFNA		ND	ND	ND	0.21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHxS		0.34	0.39	ND	ND	ND	ND	ND	ND	5.43	ND	ND	ND	ND	ND	ND
PFBS		0.27	0.28	ND	0.38	ND	ND	ND	ND	ND	3.82	ND	ND	ND	ND	ND

 Detectable Concentration

ND = Not Detected

Results are “Not Detected” when the concentration is lower than the Detection Limit.

Measurement Equivalents

1 ng/L = 1 ppt

One nanogram per liter equals one part per trillion

Contaminants Name and Acronym

Perfluorooctanoic Acid (PFOA)

Perfluorooctane Sulfonate (PFOS)

Perfluoroheptanoic Acid (PFHpA)

Perfluorononanoic Acid (PFNA)

Perfluorohexane Sulfonate (PFHxS)

Perfluorobutane Sulfonate (PFBS)

Presented are the complete PFAS sampling results from each public water system source in the Northwest Arctic Borough (2019). The Department of Environmental Conservation (ADEC) recommends drinking water samples check for 6 different PFAS contaminants. On the left are all six of the PFAS contaminant acronyms that were analyzed. The second table column shows the ADEC Action Levels which mirror the EPA Health Advisory Limit of 70 ng/L for the sum of PFOA and PFOS concentrations (PFOA and PFOS results are outlined red in the table). 11 communities were investigated and 15 different water sources were sampled.

According to ADEC’s current health guidelines, all public water system sources in the Northwest Arctic Borough have safe PFAS levels.

Generic
Maniilaq Association

Work Order: 1195746
Noatak

Client: Maniilaq Association

Report Date: October 17, 2019

Enclosed are the analytical results associated with the above work order. The results apply to the samples as received. All results are intended to be used in their entirety and SGS is not responsible for use of less than the complete report. If you have any questions regarding this report, or if we can be of any other assistance, please contact your SGS Project Manager at 907-562-2343. This document is issued by the Company under its General Conditions of Service accessible at <<http://www.sgs.com/en/Terms-and-Conditions.aspx>>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS maintains a formal Quality Assurance/Quality Control (QA/QC) program. A copy of our Quality Assurance Plan (QAP), which outlines this program, is available at your request. The laboratory certification numbers are AK00971 (DW Chemistry & Microbiology) & 17-021 (CS) for ADEC and 2944.01 for DOD ELAP/ISO 17025 (RCRA methods: 1020B, 1311, 3010A, 3050B, 3520C, 3550C, 5030B, 5035A, 6020A, 7470A, 7471B, 8015C, 8021B, 8082A, 8260C, 8270D, 8270D-SIM, 9040C, 9045D, 9056A, 9060A, AK101 and AK102/103). SGS is only certified for the analytes listed on our Drinking Water Certification, and only those analytes will be reported to the State of Alaska for compliance. Except as specifically noted, all statements and data in this report are in conformance to the provisions set forth by the SGS QAP and, when applicable, other regulatory authorities.

The following descriptors or qualifiers may be found in your report:

*	The analyte has exceeded allowable regulatory or control limits.
!	Surrogate out of control limits.
B	Indicates the analyte is found in a blank associated with the sample.
CCV/CVA/CVB	Continuing Calibration Verification
CCCV/CVC/CVCA/CVCB	Closing Continuing Calibration Verification
CL	Control Limit
DF	Analytical Dilution Factor
DL	Detection Limit (i.e., maximum method detection limit)
E	The analyte result is above the calibrated range.
GT	Greater Than
ICV	Initial Calibration Verification
J	The quantitation is an estimation.
LCS(D)	Laboratory Control Spike (Duplicate)
LLQC/LLIQC	Low Level Quantitation Check
LOD	Limit of Detection (i.e., 1/2 of the LOQ)
LOQ	Limit of Quantitation (i.e., reporting or practical quantitation limit)
LT	Less Than
MB	Method Blank
MS(D)	Matrix Spike (Duplicate)
ND	Indicates the analyte is not detected.
RPD	Relative Percent Difference
U	Indicates the analyte was analyzed for but not detected.

Note: Sample summaries which include a result for "Total Solids" have already been adjusted for moisture content.
All DRO/RRO analyses are integrated per SOP.

Warner, Nicole (Anchorage)

From: Sean Peterson <speterson@zendergroup.org>
Sent: Monday, September 30, 2019 1:08 PM
To: Warner, Nicole (Anchorage)
Cc: Charlotte Sheridan
Subject: RE: [EXTERNAL] RE: 1195746 FID/SPID

Follow Up Flag: Follow up
Flag Status: Flagged

*** WARNING: this message is from an EXTERNAL SENDER. Please be cautious, particularly with links and attachments.

Sounds great Nicole, these samples do not have to go through the ADEC drinking water program.

-----Original Message-----

From: "Warner, Nicole (Anchorage)" <NICOLE.WARNER@sgs.com>
Sent: Monday, September 30, 2019 1:04pm
To: "Sean Peterson" <speterson@zendergroup.org>
Cc: "Charlotte Sheridan" <charlotte.sheridan@maniilaq.org>
Subject: RE: [EXTERNAL] RE: 1195746 FID/SPID

Sorry for the confusion!

Generally, if we receive samples with a PWSID on the COC, we are required by ADEC to submit these for compliance, unless otherwise instructed by the client. If these don't need to go through the ADEC Drinking Water Program, then I can make a note of that and attach it to the report.

I hope this helps! Please let me know if I can clarify anything.

Thank you!

-Nicole

From: Sean Peterson <speterson@zendergroup.org>
Sent: Monday, September 30, 2019 12:06 PM
To: Warner, Nicole (Anchorage) <NICOLE.WARNER@sgs.com>
Cc: Charlotte Sheridan <charlotte.sheridan@maniilaq.org>
Subject: [EXTERNAL] RE: 1195746 FID/SPID

*** WARNING: this message is from an EXTERNAL SENDER. Please be cautious, particularly with links and attachments.

Hi Nicole,

I am confused, the samples collected are to be analyzed in the same manner as all of the other samples collected. If they submitted it with a PWSID number, I believe that because the Water Operators are helping collect the samples they are just used to doing it that way. Charlotte does this sound correct?

-----Original Message-----

From: "Warner, Nicole (Anchorage)" <NICOLE.WARNER@sgs.com>

Sent: Monday, September 30, 2019 10:18am

To: "Charlotte Sheridan" <charlotte.sheridan@maniilaq.org>, "Sean Peterson" <speterson@zendergroup.org>

Subject: 1195746 FID/SPID

Good morning!

I had a question for you regarding workorder 1195746; it looks like these were submitted with a PWSID number for the PFC analysis. We currently do not have any default values for the Facility ID/Sampling Point ID for CMDP submittal for PFCs at this time. Are these samples intended to be submitted to ADEC? If so, can you please assist with the FID/SPID values?


Thank you!

-Nicole


Nicole Warner
SGS North America, Inc
Project Manager
200 W Potter Dr
Anchorage, AK 99518
Phone: 907-562-2343
Mobile: 550-3217
E-mail: Nicole.warner@sgs.com

Information in this email and any attachments is confidential and intended solely for the use of the individual(s) to whom it is addressed or otherwise directed. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of the Company. Finally, the recipient should check this email and any attachments for the presence of viruses. The Company accepts no liability for any damage caused by any virus transmitted by this email. All SGS services are rendered in accordance with the applicable SGS conditions of service available on request and accessible at <https://www.sgs.com/en/terms-and-conditions>

Information in this email and any attachments is confidential and intended solely for the use of the individual(s) to whom it is addressed or otherwise directed. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of the Company. Finally, the recipient should check this email and any attachments for the presence of viruses. The Company accepts no liability for any damage caused by any virus transmitted by this email. All SGS services are rendered in accordance with the applicable SGS conditions of service available on request and accessible at <https://www.sgs.com/en/terms-and-conditions>



<http://www.sgs.com/terms-and-conditions>



Client pickup Date:

Be sure to ask if client will ship by ground (DOT) or air carrier (IATA)

Does a Profile exist in LIMS?

Client Name:	Maniilaq Association	
Ordered By:	Charlotte Sheraton	Phone #: 907-442-7783
Email:		
Project Name:	Noatak	Project/Permit#:
Quote #:		Profile #:
Delivery Address:	Kotzebue, Alaska (OTZ)	
	c/o Maniilaq Association	
	attn: Charlotte Sheraton 907-442-7783	

Filename: SKIT Manillaq Association Noatak 2019-09-04 *Required Items

SKIT Manillaq Association Noatak 2019-09-04

***Required Items**

[illegible]**Attention Client/Sampler:**

- | | | | |
|--------------------------|---|--------------------------|---------------------------------------|
| ☐ | Pack for Shipping via ground (DOT) | ☐ | Total # includes bottles for % Solids |
| ☐ | Pack for Shipping via air carrier (IATA) | ☐ | Track all Lot##? (Required for DOD) |
| | Temperature Blank (circle one : 120-ml OR 500-ml) | ☐ | Foreign Soil |

Other Notes/Reminders for Kit Prep:

3. Label the container with your sample ID as well as the date/time of collection.
 4. Fill out the Chain of Custody.
 5. Add frozen gel packs or ice to your cooler & pack to prevent breakage.
- Charges may be invoiced for bottles which are unused or improperly used. If you have any questions concerning this sample kit, please contact your Project Manager for assistance. Thank you.**

***This will email a copy of this form for confirmation to the client email and save the form to the network. This should not be used outside of SGS.**

☐ Custody Seals ☐ Blank COC ☐ DW COC ☐ COC initiated by PM (attached)

☐ SGS COCs - **Circle req'd format** ☐ **Note to PM:** Be sure to attach copy of requested form.

☐ Send additional instructions/documents



Chris Dankmeyer, Maniilaq Environmental Health Manager
PO Box 43, Kotzebue, Alaska 99752
Phone: 907-442-7173

Water System Name:

Noatak Utilities

Facility Name:

Noatak Utilities

Public Water System ID #:

340159

Facility ID #:

Mailing Address:

P.O. Box 41

City:

Noatak

State:

Alaska

Zip Code:

99761

Date/Time Collected:

09 / 23 / 19

Sample Collection Point:

Well # 5
Well # 6

Collected By:

Per Z. W. W. S.

12 : 30 am (pm)

Source Water Type:

☐

Flowing Stream (FS)

☐


Reservoir/Lake (RL)

☐

Other: (describe)

Groundwater

9/22

Shipper's Name and Address SGS CT and ENVIRONM 200 W Potter Drive Anchorage, AK 99518 USA Tel: 907-562-2343		Shipper's Account Number 27400215947 Customer's ID Number 9069		Not Negotiable Air Waybill Issued By  Alaska. AIR CARGO P.O. BOX 68900 SEATTLE, WA 98168 800-225-2752 ALASKACARGO.COM																			
Consignee's Name and Address SGS CT and ENVIRONM 200 W Potter Drive Anchorage, AK 99518 USA Tel: 907-562-2343		Consignee's Account Number 27400215947		Also notify Tel:																			
Issuing Carrier's Agent and City Agent's IATA Code Account No.				Accounting Information SGS CT and ENVIRONMENTAL SVS 200 W Potter Drive Anchorage, AK 99518 USA GoldStreak																			
Airport of Departure (Addr. of First Carrier) and Requested Routing Kotzebue				9069																			
To By First Carrier ANC Alaska Airlines		To / By		To / By		Currency USD PZ		WT/MAL X		Other X		Declared Value For Carriage NVD		Declared Value For Customs NCV									
Airport of Destination Anchorage		Flight/Date AS 153/25		Flight/Date		Amount of Insurance XXX																	
Handling Information														SCI									
No of Pieces 2		Gross Weight 15.0		kg L		Commodity Item No.		Chargeable Weight 16.0		Rate / Charge		Total AS AGREED		Nature and Quantity of Goods (Incl. Dimensions or Volume) WATER SAMPLES Dims: 17 x 10 x9 x 2 GSX Volume: 1.771									
2		15.0		L		16.0		AS AGREED		AS AGREED		AS AGREED		AS AGREED									
Prepaid AS AGREED		Weight Charge AS AGREED		Collect AS AGREED		Other Charges XBC 10.00																	
Valuation Charge		Tax		Total Other Charges Due Agent		Total Other Charges Due Carrier		Shipper certifies that the particulars on the face hereof are correct and that insofar as any part of the consignment contains dangerous goods, such part is properly described by name and is in proper condition for carriage by air according to the applicable Dangerous Goods Regulations. I consent to the inspection of this cargo. For: SGS CT and ENVIRONMENTAL SVS ☒ THIS SHIPMENT DOES NOT CONTAIN DANGEROUS GOODS ☐ THIS SHIPMENT DOES CONTAIN DANGEROUS GOODS															
Total Prepaid AS AGREED		Total Collect		25 Sep 2019 15:59		Kotzebue										Signature of Issuing Carrier or its Agent  Alaska Airlines							
Executed On (Date)		at (Place)		Signature of Issuing Carrier or its Agent																			
027-3725 5002																							

Alert Expeditors Inc.

#396448

Citywide Delivery • 440-3351
8421 Flamingo Drive • Anchorage, Alaska 99502

Date 9-26-19
From SGS OT2

To SGS Labs Anc

Collect ☐ Prepay ☐ Advance Charges ☐
Account ☐

Job # OT2 PO# AL 3725-5002

Sample

Shipped Signature [Signature]

Received By: [Signature] ALV 0823 Total Charge 9



e-Sample Receipt Form

SGS Workorder #:

1195746



1 1 9 5 7 4 6

Review Criteria		Condition (Yes, No, N/A)	Exceptions Noted below	
Chain of Custody / Temperature Requirements			N/A	Exemption permitted if sampler hand carries/delivers.
Were Custody Seals intact? Note # & location	Yes	1L 1R		
COC accompanied samples?	Yes			
DOD: Were samples received in COC corresponding coolers?	N/A			
N/A **Exemption permitted if chilled & collected <8 hours ago, or for samples where chilling is not required				
Temperature blank compliant* (i.e., 0-6 °C after CF)?	Yes	Cooler ID: 1	@ 2.4 °C	Therm. ID: D61
If samples received without a temperature blank, the "cooler temperature" will be documented instead & "COOLER TEMP" will be noted to the right. "ambient" or "chilled" will be noted if neither is available.		Cooler ID:	@	°C Therm. ID:
		Cooler ID:	@	°C Therm. ID:
		Cooler ID:	@	°C Therm. ID:
		Cooler ID:	@	°C Therm. ID:
*If >6°C, were samples collected <8 hours ago?		N/A		
If <0°C, were sample containers ice free?		N/A		
Note: Identify containers received at non-compliant temperature . Use form FS-0029 if more space is needed.				
Holding Time / Documentation / Sample Condition Requirements		Note: Refer to form F-083 "Sample Guide" for specific holding times.		
Were samples received within holding time?	Yes			
Do samples match COC** (i.e., sample IDs, dates/times collected)?	Yes			
**Note: If times differ <1hr, record details & login per COC.				
***Note: If sample information on containers differs from COC, SGS will default to COC information				
Were analytical requests clear? (i.e., method is specified for analyses with multiple option for analysis (Ex: BTEX, Metals))	Yes			
Were proper containers (type/mass/volume/preservative***) used?		Yes	N/A	***Exemption permitted for metals (e.g., 200.8/6020A).
Volatile / LL-Hg Requirements				
Were Trip Blanks (i.e., VOAs, LL-Hg) in cooler with samples?	N/A			
Were all water VOA vials free of headspace (i.e., bubbles ≤ 6mm)?	N/A			
Were all soil VOAs field extracted with MeOH+BFB?	N/A			
Note to Client: Any "No", answer above indicates non-compliance with standard procedures and may impact data quality.				
Additional notes (if applicable):				

Sample Containers and Preservatives

<u>Container Id</u>	<u>Preservative</u>	<u>Container Condition</u>	<u>Container Id</u>	<u>Preservative</u>	<u>Container Condition</u>
1195746001-A	Trizma	OK			
1195746001-B	Trizma	OK			
1195746002-A	Trizma	OK			
1195746002-B	Trizma	OK			

Container Condition Glossary

Containers for bacteriological, low level mercury and VOA vials are not opened prior to analysis and will be assigned condition code OK unless evidence indicates than an inappropriate container was submitted.

OK - The container was received at an acceptable pH for the analysis requested.

BU - The container was received with headspace greater than 6mm.

DM - The container was received damaged.

FR - The container was received frozen and not usable for Bacteria or BOD analyses.

IC - The container provided for microbiology analysis was not a laboratory-supplied, pre-sterilized container and therefore was not suitable for analysis.

NC- The container provided was not preserved or was under-preserved. The method does not allow for additional preservative added after collection.

PA - The container was received outside of the acceptable pH for the analysis requested. Preservative was added upon receipt and the container is now at the correct pH. See the Sample Receipt Form for details on the amount and lot # of the preservative added.

PH - The container was received outside of the acceptable pH for the analysis requested. Preservative was added upon receipt, but was insufficient to bring the container to the correct pH for the analysis requested. See the Sample Receipt Form for details on the amount and lot # of the preservative added.

QN - Insufficient sample quantity provided.



FINAL LAB REPORT

1195746

31901691

16-Oct-2019

Prepared by

SGS NORTH AMERICA

Prepared for

SGS North America Inc.

Julie Shumway

200 W. Potter Dr.

Anchorage, AK 99518

Phone: 907-562-2343

Email: julie.shumway@sgs.com

This report is approved by

Tamara Burkamper

tamara.morgan@sgs.com

Senior Project Manager

This document is issued by the Company under its General Conditions of Service accessible at https://www.sgs.com/en/terms_and_conditions. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

SGS remains committed to serving you in the most effective manner. Should you have any questions or need additional information and technical support, please do not hesitate to contact us.

The management and staff of SGS welcomes customer feedback, both positive and negative, as we continually improve our services. Please visit our web site at www.sgs.com/ultratrace and click on the 'Email Us' link or go to our survey at https://www.surveymonkey.com/r/SGSAP_VoiceOfCustomer?sm=1fj7v53XMdpUSBSUalhp2w%3d%3d. Thank you for choosing SGS.

Any holder of this document is advised that it is a final submission and supersedes and voids all prior reports with the same report or identification number. The information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility in conducting the work herein is to its Client and does not exonerate parties to a transaction from exercising all of their rights and obligations under such applicable transaction documents. This report may be reproduced in full only. The Company expressly disclaims any and all liability for the Client's use of or reliance upon the data contained herein. Any alteration, forgery or falsification of the content or appearance of this document which is not expressly authorized by the Company is unlawful and offenders may be prosecuted to the fullest extent of the law. Results reported relate only to the items tested.

Laboratory Qualifiers

Report Definitions

DL	Method, Instrument, or Estimated Detection Limit per Analytical Method
CL	Control Limits for the recovery result of a parameter
LOQ	Reporting Limit
DF	Dilution Factor
RPD	Relative Percent Difference
LCS(D)	Laboratory Control Spike (Duplicate)
MS(D)	Matrix Spike (Duplicate)
MB	Method Blank

Qualifier Definitions

*	Recovery or RPD outside of control limits
B	Analyte was detected in the Lab Method Blank at a level above the LOQ
U	Undetected (Reported as ND or < DL)
J	Estimated Concentration.
E	Amount detected is greater than the Upper Calibration Limit
TIC	Tentatively Identified Compound
ND	Not Detected
P	RPD > 40% between results of dual columns
D	Spike or surrogate was diluted out in order to achieve a parameter result within instrument calibration range

Samples requiring manual integrations for various congeners and/or standards are marked and dated by the analyst. A code definition is provided below:

M1	Mis-identified peak
M2	Software did not integrate peak
M3	Incorrect baseline construction (i.e. not all of peak included; two peaks integrated as one)
M4	Pattern integration required (i.e. DRO, GRO, PCB, Toxaphene and Technical Chlordane)
M5	Other - Explained in case narrative

Note Results pages that include a value for "Solids (%)" have been adjusted for moisture content.

Sample Summary

<u>Client Sample ID</u>	<u>Lab Sample ID</u>	<u>Collected</u>	<u>Received</u>	<u>Matrix</u>
Well # 5	31901691001	09/23/2019 11:45	10/02/2019 10:09	Drinking Water
Well # 6	31901691002	09/23/2019 12:10	10/02/2019 10:09	Drinking Water

Results of Well # 5

Client Sample ID: **Well # 5**
 Client Project ID: **1195746**
 Lab Sample ID: 31901691001-A
 Lab Project ID: 31901691

Collection Date: 09/23/2019 11:45
 Received Date: 10/02/2019 10:09
 Matrix: Drinking Water
 Solids (%):

Results by EPA 537 v1.1

<u>Parameter</u>	<u>Result</u>	<u>Qual</u>	<u>DL</u>	<u>LOQ/CL</u>	<u>Units</u>	<u>DF</u>	<u>Date Analyzed</u>
PFHpA	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
PFOA	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
PFNA	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
PFBS	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
PFHxS	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
PFOS	ND	U	0.196	1.96	ng/L	1	10/15/2019 18:26
Surrogates							
13C2-PFHxA	94.0			70.0-130	%	1	10/15/2019 18:26
13C2-PFDA	99.8			70.0-130	%	1	10/15/2019 18:26
d5-NEtFOSAA	91.7			70.0-130	%	1	10/15/2019 18:26

Batch Information

Analytical Batch: **XLC1404**
 Analytical Method: **EPA 537 v1.1**
 Instrument: **TQS2**
 Analyst: **FNS**

Prep Batch: **HXX2427**
 Prep Method: **EPA 537 v1.1 Prep**
 Prep Date/Time: **10/04/2019 14:26**
 Prep Initial Wt./Vol.: **255 mL**
 Prep Extract Vol: **1 mL**

Results of Well # 6

Client Sample ID: **Well # 6**
 Client Project ID: **1195746**
 Lab Sample ID: 31901691002-A
 Lab Project ID: 31901691

Collection Date: 09/23/2019 12:10
 Received Date: 10/02/2019 10:09
 Matrix: Drinking Water
 Solids (%):

Results by EPA 537 v1.1

<u>Parameter</u>	<u>Result</u>	<u>Qual</u>	<u>DL</u>	<u>LOQ/CL</u>	<u>Units</u>	<u>DF</u>	<u>Date Analyzed</u>
PFHpA	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
PFOA	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
PFNA	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
PFBS	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
PFHxS	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
PFOS	ND	U	0.200	2.00	ng/L	1	10/15/2019 19:00
Surrogates							
13C2-PFHxA	101			70.0-130	%	1	10/15/2019 19:00
13C2-PFDA	106			70.0-130	%	1	10/15/2019 19:00
d5-NEtFOSAA	97.5			70.0-130	%	1	10/15/2019 19:00

Batch Information

Analytical Batch: **XLC1404**
 Analytical Method: **EPA 537 v1.1**
 Instrument: **TQS2**
 Analyst: **FNS**

Prep Batch: **HXX2427**
 Prep Method: **EPA 537 v1.1 Prep**
 Prep Date/Time: **10/04/2019 14:26**
 Prep Initial Wt./Vol.: **250 mL**
 Prep Extract Vol: **1 mL**

Sample Receipt Checklist (SRC)

Work Order No.: **31901691**

- Comments: _____
- _____
- _____
- _____

Date: 10/2/2019